



TOWNSHIP OF FREEHOLD

DEPARTMENT OF HOUSING & ZONING ENFORCEMENT

1 Municipal Plaza, Freehold, NJ 07728

(732)294-2066 or (732) 294-2050

Housing@twp.freehold.nj.us

REQUIREMENTS FOR CERTIFICATE OF CONTINUED OCCUPANCY (C.C.O.) & FIRE INSPECTIONS

For Resale and Rental of ALL Residential Homes

IT IS RECOMMENDED THAT ALL BUYERS PERFORM A PRIVATE HOME INSPECTION SINCE THE TOWNSHIP INSPECTIONS ARE SAFETY INSPECTIONS.

CHECKLIST FOR C.C.O. INSPECTION

PERMITS	-All permits must be closed. Please check with the Construction Dept or call 732-294-2050. -Any work performed without necessary Construction or Zoning permits will require the property owner to apply for and close out the permit(s) before the C.C.O. is issued (Examples: Hot water heaters, furnaces, AC, decks, sheds, fences, finished basements, etc.)
WELL / SEPTIC	-Properties with well and/or septic require approval by the Health Department. The dept is located in the Town Hall building or call directly for requirements @ 732-294-2060.
UTILITIES	-All utilities must be on.
EXTERIOR	-House number must be 6 inches high, visible from the street and contrasting color from the house. -Property must be in good condition and free of debris.
WINDOWS	-All must be in working order with no broken seals and all must have screens.
DOORS	-All entry doors that have deadbolt locks must have a thumb latch on the inside. NO DOUBLE KEY DEAD BOLTS OR SLIDE BOLT LOCKS ARE PERMITTED. -All interior doors must be operational with hardware. -Privacy type doorknobs are allowed for bedrooms & bathrooms only (lock must be inside only). -Glass sliding doors must be in working order.
RAILINGS	-Handrails should be firmly fastened. -4 risers and more require a hand railing.
KITCHEN	-All appliances must be in working order.
BATHROOM	-Sinks, tubs, showers and toilets must be in working order. -A vent fan is required if there is no operable window.
FLOORS	-Smooth and free of tripping hazards. -No carpeting permitted in kitchens and bathrooms.
PLUMBING	-Fixtures must be properly installed and in working order.
ELECTRICAL	-GFCI outlets are required within 6ft of <u>ALL SINKS</u> (kitchen sink, bathroom sinks, bars & slop sinks). -Outlets, switches and junction boxes must be properly covered.
GARAGE	-Solid core wood or steel doors with a minimum 20-minute fire rating are required for entrances from the garage. -Electric garage door openers must have their own outlet. No extension cords. -Attic stairs in a garage must be fire rated and have a permit.

WASHER/DRYER	-Washer must discharge into drainage system. -Dryer vents must be flexible metal type, no plastic. The vent must be as straight/short as possible. No looping of the vent allowed.
SUMP PUMP	-Must have its own single outlet (no extension cords). -Pump must discharge to the exterior of the home and not into sewer lines.
POOL	-Pool gates must be self-closing and self-latching. -Pool must be running or closed.
GENERAL	-Any violation found by the inspector that he/she deems a safety issue must be addressed even if it is not on this list.

RENTAL PROPERTIES ONLY	-Every Rental property must be registered with the town. -Property owners must obtain a C.C.O. & Fire inspection whenever there is a change in occupancy. -Property must be vacant at the time of inspection. -Must be properly cleaned/sanitized, rugs must be shampooed and must be freshly painted prior to the inspection. -Tenant names are required.
-------------------------------	--

New Jersey Residential Smoke Alarm, Carbon Monoxide and Fire Extinguisher Requirements

New Jersey Uniform Fire Code N.J.C. 5:70-4.19

****CHECKLIST FOR FIRE INSPECTION****

SMOKE DETECTORS	-Functioning units are required on every level of the home including the basement and installed within 10 ft of all bedrooms. -All detectors/alarms must be replaced every 10 years. -Homes built prior to 1981 which have only battery operated smoke detectors/alarms (and not interconnected hardwired alarms) are required to be replaced with a 10 year sealed battery powered single station unit. <i>(Please see detailed fire requirements page.)</i>
CARBON MONOXIDE	-CO detector/alarms are required within 10 ft of all bedrooms in the immediate hallway. If there is no outlet in the hallway, then a battery-operated unit is needed. If bedrooms are more than 10 ft apart, two are required. <i>(Please see detailed fire requirements page.)</i>
FIRE EXTINGUISHER	-All residential properties must have a fire extinguisher in the kitchen. -The extinguisher must be have a minimum rating of <u>2A-10B:C and no more than 10 lbs</u> and must be tagged (indicating that it was serviced by a Division of Fire Safety contractor within the last 12 months) OR <u>NEWLY PURCHASED.</u> <u>-MUST BE MOUNTED</u> on the manufacturer's provided bracket at a height no greater than 5ft above the floor to the top of the extinguisher. -Must be accessible & visible, not behind a closed door or cabinet.

*****For properties that cannot pass C.C.O. inspection prior to closing, please see "TRANSFER OF TITLE – NO OCCUPANCY" .**i>***